

Parámetros de Calidad de Gas a introducir en los conversores PTZ durante el Primer Semestre de 2021



Posición Position	PCS SCV kWh/m3 (n)	PCI ICV kWh/m3 (n)	Densidad Density	N2 % mol	CO2 % mol	Variación PCS %
15	11,646	10,497	0,615	1,100	0,985	-1,03%
15.02	11,646	10,497	0,615	1,100	0,985	-1,03%
15.12	11,612	10,468	0,625	1,549	1,450	-1,01%
15.13	11,612	10,468	0,625	1,549	1,450	-1,01%
15.14	11,612	10,468	0,625	1,549	1,450	-1,01%
15.15.01	11,612	10,468	0,625	1,549	1,450	-1,01%
15.15.02	11,612	10,468	0,625	1,549	1,450	-1,01%
15.15A	11,612	10,468	0,625	1,549	1,450	-1,01%
15.16A	11,612	10,468	0,625	1,549	1,450	-1,01%
15.20.05	11,612	10,469	0,629	1,662	1,610	-1,07%
15.20.5EGT	11,612	10,469	0,629	1,662	1,610	-1,07%
15.20.06	11,611	10,468	0,629	1,676	1,598	-1,05%
15.20.6EGT	11,611	10,468	0,629	1,676	1,598	-1,05%
15.21	11,610	10,465	0,621	1,349	1,311	-1,04%
15.22	11,610	10,465	0,621	1,349	1,311	-1,04%
15.22A	11,610	10,465	0,621	1,349	1,311	-1,04%
15.23	11,610	10,465	0,621	1,349	1,311	-1,04%
15.24	11,610	10,465	0,621	1,349	1,311	-1,04%
15.24.1	11,610	10,465	0,621	1,349	1,311	-1,04%
15.24.1-01	11,610	10,465	0,621	1,349	1,311	-1,04%
15.24A	11,610	10,465	0,621	1,349	1,311	-1,04%
15.26	11,610	10,465	0,621	1,349	1,311	-1,04%
15.26A	11,610	10,465	0,621	1,349	1,311	-1,04%
I013.REG	11,591	10,432	0,585	0,131	0,000	-1,38%
K48.08	11,602	10,461	0,629	1,718	1,644	-1,12%
B22.1	11,562	10,418	0,612	0,830	1,302	-