

Parámetros de Calidad de Gas a introducir en los conversores PTZ durante el Primer Semestre de 2022



Posición Position	PCS SCV kWh/m3 (n)	PCI ICV kWh/m3 (n)	Densidad Density	N2 % mol	CO2 % mol	Variación PCS %
4	11,783	10,618	0,600	0,316	0,114	1,20%
1.01	11,789	10,623	0,598	0,242	0,000	1,29%
1D	11,780	10,615	0,598	0,246	0,000	1,21%
4.03	11,777	10,612	0,600	0,299	0,110	1,15%
4.07.36	11,777	10,612	0,600	0,299	0,110	1,12%
4.07.45	11,777	10,612	0,600	0,299	0,110	1,12%
5D.04	11,777	10,612	0,600	0,299	0,110	1,12%
5D.06	11,777	10,612	0,600	0,299	0,110	1,12%
ERP01-01	11,777	10,612	0,600	0,299	0,110	1,12%
B35X	11,791	10,625	0,598	0,245	0,005	1,28%
ERPA36-01	11,791	10,625	0,598	0,245	0,005	1,28%
I015.REG	11,587	10,434	0,593	0,436	0,262	-1,18%
I016.1	11,689	10,530	0,593	0,199	0,086	1,03%
I016-A	11,689	10,530	0,593	0,199	0,086	1,03%
I016V	11,689	10,530	0,593	0,199	0,086	1,03%
I018	11,689	10,530	0,593	0,199	0,086	1,03%
I019	11,689	10,530	0,593	0,199	0,086	1,03%
I020	11,689	10,530	0,593	0,199	0,086	1,03%
I020A	11,689	10,530	0,593	0,199	0,086	1,03%
I022	11,689	10,530	0,593	0,199	0,086	1,03%
I022.3	11,689	10,530	0,593	0,199	0,086	1,03%
I022.4	11,689	10,530	0,593	0,199	0,086	1,03%
I023	11,689	10,530	0,593	0,199	0,086	1,03%
I024	11,689	10,530	0,593	0,199	0,086	1,03%
I025	11,759	10,595	0,596	0,145	0,051	1,64%
O05.1.06	11,646	10,492	0,600	0,465	0,470	-1,12%
O09	11,652	10,498	0,601	0,473	0,500	-1,05%
O11	11,652	10,498	0,601	0,473	0,500	-1,05%
O12	11,652	10,498	0,601	0,473	0,500	-1,05%
O14	11,652	10,498	0,601	0,473	0,500	-1,05%
O14.1	11,652	10,498	0,601	0,473	0,500	-1,05%
O14.1TRG	11,652	10,498	0,601	0,473	0,500	-1,05%
O14A	11,652	10,498	0,601	0,473	0,500	-1,05%
O16	11,652	10,498	0,601	0,473	0,500	-1,05%
O17	11,652	10,498	0,601	0,473	0,500	-1,05%
P01	11,652	10,498	0,601	0,473	0,500	-1,05%
P03	11,652	10,498	0,601	0,473	0,500	-1,05%